

Himachal Pradesh  
Jal Shakti Vibhag

No.JSV-SE (P&I-I)-D-I-Tech- Comm. (Product)-2021-22- 1225-32 Dated:- 20.7.2021


To

The Chief Engineer,  
Shimla Zone, Mandi Zone,  
Hamirpur Zone, Dharamshala Zone,  
Jal Shakti Vibhag, Himachal Pradesh.

**Subject: Minutes of 4<sup>th</sup> State Level Technical Committee Meeting held on 07.07.2021 at Jal Shakti Bhawan, Shimla-5.**


Enclosed please find herewith the minutes of 4<sup>th</sup> State Level Technical Committee meeting for the year 2021-22 held on 07.07.2021 at Jal Shakti Bhawan for your kind information and necessary action.

DA: As above

  
Engineer-in-Chief (JSV),  
Jal Shakti Bhawan,  
Shimla-05.

Copy to:

1. The Secretary (JSV) to the Govt. of Himachal Pradesh Shimla-01 for information please.
2. The Chief Engineer cum Director (WSSO), Jal Shakti Vibhag, Jal Shakti Bhawan, Shimla-05 for information please.
3. The Superintending Engineer (Works), Jal Shakti Vibhag, Jal Shakti Bhawan, Shimla-05 for information please.
4. The Joint Controller (F&A), Jal Shakti Vibhag, Jal Shakti Bhawan, Shimla-05 for information please.

  
Engineer-in-Chief (JSV),  
Jal Shakti Bhawan,  
Shimla-05.

**Minutes of 4th State Level Technical Committee (Products) meeting for FY 2021-22 held on 07.07.2021 under the Chairmanship of Engineer-in-Chief (JSV) at Jal Shakti Bhawan, Shimla -5.**

4<sup>th</sup> meeting of the State Level Technical Committee (Products) to process the proposals of various Firms/ companies for registration and approval of their products/ services was held under the Chairmanship of Engineer-in- Chief (JSV) at Jal Shakti Bhawan, Shimla -5 on 07.07.2021 through Video Conferencing.

At the outset, the Superintending Engineer (P&I-I) welcomed the Chairman and all the members to 4<sup>th</sup> meeting of SLTC for FY 2021-22.

List of participants is as per Annexure "A" attached.

Accordingly, agenda items were taken up for discussion one by one as below:

**I. Budget Assurance 2021-22 regarding inclusion of Rural Sewerage under MLA Priorities and Drafting of Guidelines-**

The Chairman apprised the Committee about the urgent requirement of finalizing the guidelines for processing of the DPRs and asked the CE (D/Z), (M/Z) & (S/Z) to submit the comments at the earliest, so that guidelines be drafted & submitted to the government.

**II. Proposal of the products received for registration-**

Sr. No	Name of Firm/ Vendor/ Testing Agency/ Manufacturer	Address	Product/ Services applied for registration	Product Range	Material of Construction of product	Product/ Service Classification	Decision of the Committee
1	M/s Shree Siyaram Switchgears Pvt. Ltd.	B-9, Navjeevan Complex, Station Road, Jaipur-302006 Contact No: 09602142150 Email: <a href="mailto:info@atlantech.in">info@atlantech.in</a>	Introduction of ATLANTECH make Electromagnetic Flow Meter	upto 600mm		Flow Meters	The committee decided that the firm may undertake a demonstration of their product free of cost under JSV Circle Una & present the results of the same before committee thereafter.
2	M/s Eureka Industrial Equipment Private Limited	1st Floor, Royal Chambers, Paul Road, Pune-411038 (India) Contact No: 91-20-254479 25461314	Introduction & request for approval of "Eureka" make Electromagnetic & Ultrasonic	3 mm to 3000 mm	<b>Electrode Material:</b> SS316 L, Nickel alloy, Tantalum, Platinum +	Flow Meters	The committee decided that the firm may undertake a demonstration of their product free of cost under JSV Circle Solan & present the results of the same before committee thereafter.

*[Handwritten signature]*  
A.E.

	3	M/s FLOW Systems Pvt. Ltd., IOTA Systems Ltd., A-2/13, Mayapuri, Industrial Area, Phase-II, New Delhi-110064. Contact No: 9315526661 Email: contact@iotaflow.com jb@iotaflow.com	Email: sales@eurekaflow.com	Flow Meters.	Empanelment / Sanction of approval for Iota flow makes Flow Meters in water & sewerage improvement programs.	100 mm to 1400 mm	iridium, Titanium, Tungsten Carbide, Hastelloy C	Flow Meters	The firm didn't present its product before the committee. Hence, the committee deferred the proposal for next meeting.
	4	M/s Darling India Muesco Pvt. Ltd Plot No. 97/A, Phase-I, GIDC. Estate, Vavta, Ahemdabad-382 445 Gujrat India Contact No: 07929703356 Email: sales@darlingmuesco.com	Vendor registration			Flow Control Valve		Flow Control Valve	The committee decided that the firm may undertake a demonstration of their product free of cost under JSV Circle Nahan & present the results of the same before committee thereafter.
	5	M/s Krishna & Equipment Construction Technologies Plot No. 1361, JLPL Industrial Park, Sector 82, SAS Nagar, Mohali-160065 (Punjab) Contact No: 91-97791-25434 Email: Kect_rahul@yahoo.com	Introduction of "DVD" valves, Clamps compact Dismantling Joints: Request for trial, approval & inclusion of DVD make in Jal Shakti Vibhag (Govt. Himachal	Gate Valve: DN 40MM-DN 600MM Needle Valve: DN 80MM-DN 1600MM Check Valves: DN 40MM-DN 1000MM		Gate Valves & Butterfly Valves, Air Valves, Control Valves, Check Valves and Hydrants		Gate Valves & Butterfly Valves, Air Valves, Control Valves, Check Valves and Hydrants	The committee decided that the firm may undertake a demonstration of their product free of cost under JSV Circle Una & present the results of the same before committee thereafter.

MA A.E.

			Pradesh)	<p><b>Air Valves:</b> DN 40MM-DN 500MM <b>Butterfly Valves:</b> DN 100 MM-DN 500MM <b>Irrigation Hydrants:</b> DN 80MM-DN 200MM <b>Fire Hydrants:</b> DN 80MM-DN 100MM</p>						
6	M/s Alpine Flowtech	Unit No. 1, B wing, Swarajya complex, Rajlaxmi Compound, Opp. Bewakoof Textile Factory Outlet, Kasheli, Kalher, Tal Bhiwandi Distt. Thane. Contact No: 9324515987 8978558585 Email: alpineflowtech@gmail.com	Approval and Registration request of ALPINE & AFC & VARIE make valves in the Approved Vendor List in I&PHE Department	50mm to 500 mm 500mm to 900 mm	Direct Acting PRV, Float Valve, Strainer for House Service connections.	The committee decided that the firm may undertake a demonstration of their product free of cost under JSV Circle Bilaspur & present the results of the same before committee thereafter.				
7	M/s Anco Motors	Plot No.45/46/47, Shree Shakti Udyog Nagar, Palghar Manor Road, Palghar-401404.	Request for registration/empanelment of our brand/	6" Submersible Pumps (upto	Submersible Pumps	The committee decided that the firm may undertake a demonstration of their product free of cost under JSV Circle				

*mf A.S.*

		<p>Contact No: 9820322386 91-22014461 Email: <a href="mailto:adminoffice@ansonsancopumps.com">adminoffice@ansonsancopumps.com</a></p>	<p>products "anco"- &amp; Pumpsets motors.</p>	<p>30HP/22.4 KW) 6" Water Filled Rewindable Motors (upto 40HP/30 KW) 4" Submersible Pumps (upto 7.5 HP/5.6 KW) 4" Water Filled Rewindable Motors (upto 35HP/1.5 KW)</p>		<p>Sundernagar &amp; present the results of the same before committee thereafter.</p>
8	<p>M/s Ansons Electro Mechanical Works</p>	<p>Kakkad House, 'B' Wing, Flat No.'F' 5th Floor, Barrack Road, Dhobi Talao, Mumbai-400020. Contact No: 9672855356 91-22010605 Email: <a href="mailto:sangives@ansonsancopumps.com">sangives@ansonsancopumps.com</a></p>	<p>Request for registration/ empanelment of our brand/ products" anco"- Pumpsets &amp; motors.</p>	<p>Horizontal Openwell Submersibles (upto 10.0 HP/7.5KW) Vertical Openwell Submersibles (upto 20.0 HP/15KW) Monobloc Pumps (from 3HP/2.2 KW to</p>	<p>Submersible Pumps</p>	<p>The committee decided that the firm may undertake a demonstration of their product free of cost under JSV Circle Sundernagar &amp; present the results of the same before committee thereafter.</p>

*not A/E*

9	M/s Prince Pipes and Fittings	The Ruby, 8th Floor; 29, Senapati Bapat Marg (Tulsi pipe Road), Dadar (W), Mumbai-400 028, Maharashtra, India. Contact No: 9888927755 Email: info@princepipes.com rsb@princepipes.com	To demonstrate PPR-C pipes with quality products.	20HP/15 KW) Flameproof Motors (upto 1 HP/0.75 KW)	PPR	CPCV, UPVC, PP-R, SWR, PVC, UDS, Borewell, Roof Water, Chamber & Manhole Cover etc.	The committee decided that the firm may undertake a demonstration of their product free of cost JSV Circle Reckong Peo & present the results of the same before committee thereafter.
10	M/s Aditya Irrigation technologies Pvt. Ltd	# 4&5 Kalikanagar Andrahali Main Road, Vihawaneedam Post, Bangalore Karnataka-560091 E-mail- aditya.irrigation@gmail.com	Regarding Promotion and Supply of HDPE pipes for various application: Approval of vendor registration).	20mm to 110 mm with PN 2.5 kg/cm2 to 16 Kg/cm2	HDPE	Pipes	The firm didn't present its product before the committee. Hence, the committee deferred the proposal for next meeting.
11	M/s Bharat Polymers	Plot No. 256, Sector-3, HSIIDC, Karnal-132001 Contact No: 98966-51909 72060-70004 72060-70005 E-mail- Bharatpolymers@gmail.com	Regarding our empaneling in your Department for HDPE piping solutions	32mm-200mm	HDPE	IS: 4984:2016 (PE-100, PE-63 from 32-200 mm across all pressure classes)	The firm didn't present its product before the committee. Hence, the committee deferred the proposal for next meeting.

*M. V. S.*

12	M/s Tirupati Structural Limited	Plot No. 81, F.I.E. Patparganj, Delhi-110092. Contact No: 011-43041400 E-mail- <a href="mailto:info@tirupatipipes.com">info@tirupatipipes.com</a>	Request for empanelment	HDPE/PVC Pipes and Fittings	IS:14151 Part(1) IS:14151 Part(2) HDPE/PV C Pipes and Fittings	The committee decided that the firm may undertake a demonstration of their product free of cost under JSV Circle Kullu & present the results of the same before committee thereafter.
13	M/s SFC Environmental Technologies Pvt. Ltd. (C-tech)	21st Floor, The Ambience Court, Hi-Tech, Business Park, Plot No 2, Sector 19D, Vashi, Navi Mumbai-4007 705 Contact No: 0-22-27832646 E-mail- <a href="mailto:info@ctechsbr.com">info@ctechsbr.com</a>	Request regarding approval of the technology on upcoming STP's in Himachal Pradesh.		SBR Technology	The firm is already working in the State especially in the SJPNL projects. Therefore, the firm may participate in the tendering.
14	M/s Telemachus High-Tech Pvt. Ltd.	Branch Office Ashwini Sadan, 2/327, Vivek Khand, Gomti Nagar, Lucknow-226010 Contact No.- 09958738882 Email: <a href="mailto:telemachus.in@gmail.com">telemachus.in@gmail.com</a> <a href="mailto:telemachusdelhi@gmail.com">telemachusdelhi@gmail.com</a>	ISR Modular Technology used for Bioremediation treatment of Sewage water coming out of buildings, colonies, societies and flowing directly into drains, river, with oil spill eater (OSE)-II Enzyme-Patented in USA-space		(Flow control valve NRV Valve, Saddle, Elbow etc.)	It was decided that the Chief Engineers will submit the comments, regarding use of the technology.

15	M/s Pumpco India	Plot No. 153 Phase-2 Panchkula Contact No. 7650098311 Email: <a href="mailto:PumpcoIndia@gmail.com">PumpcoIndia@gmail.com</a>	requires 100-250 S.Mtr. area. Request for proposal of undertaking of Pumping stations in H.P. under ESCO Model through PP mode.				Replacem ent / up gradation of old pumping machinery	The committee directed the firm to carryout feasibility study under JSV circle Solan free of cost.
16	Energy Efficiency Services Limited	1st Floor, Thakur Niwas, Opp. HDFC Life, Khalini, Shimla-171002. Contact No. <a href="mailto:mkaushal@eesl.co.in">mkaushal@eesl.co.in</a>	Regarding Proposal for deployment of E-Vehicles.					The committee decided that the firm shall submit the detailed proposal after clarifications from the office of SE P&I-1.
17	M/s Shyam Future Tech.	Shyam Towers, EN 32 sector V, Salt Lake, Kolkata-700091 India. Contact No.- 03340074004 Email: <a href="mailto:contact@shyamfuture.com">contact@shyamfuture.com</a>	E office Solution Mobile Application. These solutions include productivity enhancing applications like project Management System, Vendor management system, Etask etc.					The firm didn't present its product before the committee. Hence, the committee decided to drop the proposal.
18	M/s Tintometer India Pvt. Ltd.	Hyderabad Contact No. 040238-83300 Email: <a href="mailto:indiaoffice@lovibond.in">indiaoffice@lovibond.in</a>	Regarding Pre-programmed Water Instrument and Kits for demo.					The firm didn't present its product before the committee. Hence, the committee decided to drop the proposal.



**III. Proposal for which the registration process completed and require approval of the committee.**

S. No	Subject	Address	Latest Status	Decision of the Committee
1	Empanelment of our made/ product (water proofing Chemical Materials)	M/s Home Care Traders H.O, Sanouran, Tiara Road, Near Mount Carmal School Gaggal (Kangra) H.P. Contact No. 9816031700 8625900001 Email: <a href="mailto:homecaretraders617@gmail.com">homecaretraders617@gmail.com</a>	The Superintending Engineer Dharamshala has submitted the detail of make model and specification of installed product duly recommended with EE JSV Division Dharamshala vide letter no.1782-83 dt. 9.06.2021. Eniroof EMB™, SPR, Aquagaard™ 50%, DI Primer & Fiberglass Cloth.	The Committee decided to approve the Eniroof EMB™, SPR, Aquagaard™ 50%, DI Primer & Fiberglass Cloth for water proofing.
2	Request for approval of "RG" brand cast steel (CS) Air valves, Butterfly vales and swing check type reflux (non-return) valves.	M/s R.G. Industries vill Fazalpur, Behind Focal Point, Near Randhawa Masadan, Jalandhar-144004 (PB). Contact No.0181-2600220 Email: <a href="mailto:enquiry@rgindustriessachdeva.com">enquiry@rgindustriessachdeva.com</a>	The performance report of Cast Steel Swing Check Type (Non reflux) valve and Cast Steel Air valve has been received from SE IPH Circle Una vide letter No. 3515-20 dated 18.06.2021. As per the report received, the performance of the product has been found satisfactory and recommended for its use in the department.	The Committee decided to approve the Cast Steel Swing Check Type (Non reflux) valve and Cast Steel Air valve of RG make.
3	Request for approval of "SACHDEVA" brand Cast Steel (CS)& CI (Sluice Valves).	M/s Sachdeva Metal Works C-33, Focal Point Extension Jalandhar-144004 (PB). Contact No.- 0181-5057999 Email: <a href="mailto:smw@rgindustriessachdeva.com">smw@rgindustriessachdeva.com</a>	The performance report of Cast Steel Sluice valve has been received from SE IPH Circle Una vide letter No. 3515-20 dated 18.06.2021. As per the report received, the performance of the product has been found satisfactory and recommended for its use in the department.	The Committee decided to approve the Cast Steel Sluice valve of SACHDEVA Make.

4	Engagement of ELI Technical Economic Services (EliTes) India Pvt. Ltd for 3 <sup>rd</sup> party inspection of stores and project Monitoring.	M/s ELI Technical Economic Services India Pvt. Ltd. Office R-18, 1 <sup>st</sup> Floor, Shakarpur- Vikas Marg, Delhi-110092. Contact No. 011-22055670 Email: <a href="mailto:elitesindiapl@gmail.com">elitesindiapl@gmail.com</a>	The firm has submitted all the relevant documents, which were found in order.	The committee decided to empanel the firm as 3 <sup>rd</sup> party inspection of stores and project Monitoring.
5	Provision of Restrained Joints DI Pipes and Fittings in Water Supply and Irrigation DPR's.	M/s Electro steel Casting Ltd. B-47 Shiv Mahal Cannaught Place New Delhi-110001 India. Contact No.- 8588833676 E-mail- <a href="mailto:parvezhakim@electrosteel.com">parvezhakim@electrosteel.com</a> <a href="mailto:Parvez444@hotmail.com">Parvez444@hotmail.com</a>	The firm has submitted the detailed specifications of the restrained joints as decided during previous meeting.	The committee decided to approve the use of Restrained Joints DI Pipes and Fittings in the department.

**IV. Review of proposals of the product for which demonstration projects have been assigned during previous meetings.**

S. No	Subject	Address	Product Details/Remarks	Comments/ Action Required to be taken
B. I.	<b>Firms called for Presentation for the meeting held on 08-07-2019</b>			
3	Regarding Approval and Registration request of Durga/ DVPL/ Singer make valves in your department and various projects.	M/s Durga valves private limited Ichappur Road, Canal Side Santragachi Howrah-711104 (WB). Contact No. 033-2677 8088 Email: <a href="mailto:info@durgavalves.com">info@durgavalves.com</a> m <a href="mailto:Kolkatta@durgavalves.com">Kolkatta@durgavalves.com</a>	It was decided by the committee that a reminder be issued to the firm to contact the SE Circle Nahan.	To issue reminder to the SE JSV Circle Nahan/firm.  <b>Action By:</b> Superintending Engineer, JSV Circle Nahan.

*M. S.*

6	Incorporating in the approved Vendor list of Electro-Mechanical Equipment's for WTP/ STP/ EAP namely; Clarifier, Thickener, Clariflocculator, Flash Mixer, Flocculator & De-gritting Mechanisms of all Sizes.	M/s Indofab Industries C/3-4-5, Hatkesh Udyog Nagar, Kashimira Bhayander Road Post: Mira, Dist. Thane, Maharashtra-40104. Contact No. 91-22-2811326/ 28113414 Email: <a href="mailto:sales@indofab.com">sales@indofab.com</a> <a href="mailto:operations@indofab.com">operations@indofab.com</a>	CE (H/Z) vide his office letter No. 10808 dated 21.11.2019 has requested to supply a copy of documents presented before the committee by the firm. Scanned copy of document presented by the firm has been emailed to CE (H/Z) through email. As per decision of the committee, letter (No. 1360-68 Dated 08.09.2020) was issued to the Chief Engineer Hamirpur Zone.	To issue reminder to the Chief Engineer (HZ).  <b>Action By:</b> The Chief Engineer (HZ).
8	Regarding Technical Presentation on SFMC Brand, PP-R pipes & fittings.	M/s SFMC Co. Pvt. Ltd., Lal Rattan building Basement, West Patel Nagar, Near Satyam Cinema, New Delhi-110008 Contact No. 91-11-25798982 Email: <a href="mailto:enquiry@sfmc-india.com">enquiry@sfmc-india.com</a> <a href="mailto:info@sfmc-india.com">info@sfmc-india.com</a>	During the meeting held on 13-02-2021 the CE (SZ) had informed that these pipes have been installed in R/Peo Circle and not functioning well.  The committee asked the CE(S/Z) to submit the report in next meeting.	To issue reminder to the Chief Engineer (SZ).  <b>Action By:</b> The Chief Engineer (SZ).
<b>B. Firms called for technical details on 31-10-2019</b>				
4	Regarding approval "Topland Engineers Pvt. Ltd." Make Diesel Pumps Sets, Submersible Pump Sets, Generating Sets etc.	M/s Topland Engineers Pvt. Ltd. 2-Umakant Pandit Udyognagar, Mavdi Plot, Rajkot-360004 (Gujrat). Contact No. 91-281-2360222-3-4 91-94288 89427 Email: <a href="mailto:salesrajkot@topland-india.com">salesrajkot@topland-india.com</a>	During the 2 <sup>nd</sup> of SLTC held on 31.10.2019 it was decided that the firm shall undertake a demonstration project.	To issue reminder to the Chief Engineer (HZ)/Firm.  <b>Action By:</b> The Chief Engineer (HZ).

M.F.A.C.

	<p>Regarding Introduction of Brand name "R&amp;D Multiples" for approval.</p>	<p><a href="mailto:amm@topland-india.com">amm@topland-india.com</a>  M/s R&amp;D Multiples (Metal Cast) Pvt. Ltd., 106, United Industrial Estate, Mogul, Mahim (W) Mumbai-400016.  Contact No. 022-4004 4425 to 4004 4430, 91-9004031331  Email: <a href="mailto:pardi@rdmultiples.com">pardi@rdmultiples.com</a>, <a href="mailto:bhupesh@rdmultiples.com">bhupesh@rdmultiples.com</a></p>	<p>During the 2<sup>nd</sup> of SLTC held on 31.10.2019 it was decided that official of the department may visit to the manufacturing unit of the firm.</p>	<p>To issue reminder to the Chief Engineer (MZ)/Firm.   <b>Action By:</b> The Chief Engineer (MZ).</p>
8	<p>Application for approval of Brand for the products Open-well &amp; Bore well Submersibles, Centrifugal Mono-bloc Pumps.</p>	<p>M/s Angel Pumps (P) Limited.  Contact No. 91 2827 287150-51 52  Email: <a href="mailto:info@pumpsangel.com">info@pumpsangel.com</a></p>	<p>During the 2<sup>nd</sup> of SLTC held on 31.10.2019 it was decided that the firm shall undertake a demonstration project for submersible Pump only in the Department.</p>	<p>To issue reminder to the Chief Engineer (DZ)/Firm.   <b>Action By:</b> The Chief Engineer (DZ).</p>
11	<p>Empanelment of Third party inspection Agency.</p>	<p>M/s International Quality Management Services  Contact No. 0129-4179696  Email: <a href="mailto:info@iqms.biz">info@iqms.biz</a></p>	<p>To issue letter to SE JSV Circle Solan to send a team to visit the manufacturing /testing unit of the firm (FOR PVC and HDPE pipes Only).</p>	<p>To issue reminder to the SE JSV Circle Solan/Firm.   <b>Action By:</b> Superintending Engineer, JSV Circle Solan</p>
<b>C Items for Internal Discussions</b>				
2	<p>Approval of PPR Pipe</p>	<p>Kanha Plastic Pvt. Ltd.122/69, central Hope Town, Salauki Industrial Area, Dehradun-248197.</p>	<p>Firm has already done department project at Dharamshala with fitting like Union Gate Valve, FTS, Elbow, FTT Socket. Etc.</p>	<p>To issue reminder to the CE (SZ)/Firm.</p>

	<p>Contact No. -91(0135) 2698202, 8447570575 98883-33119</p> <p>Email: narinder@kptpipes.com info@kptpipes.com</p>	<p>During the meeting held on 13.02.2021 the CE (SZ) had informed that these pipes have been installed in R/Peo Circle and there is leakage problem in joints and functioning of the pipes is not suitable to the specific condition of site.</p> <p>The committee asked the Chief Engineer (S/Z) to submit the report in next meeting.</p>	<p><b>Action By:</b> The Chief Engineer (SZ).</p>
3	<p>M/s Maccaferri Environmental Solution Pvt. Ltd.</p> <p>Contact No. 91-9650022179</p> <p>Email: a.shaaz@maccaferri.com</p>	<p>The committee decided to issue the letter to the firm to take demonstration of site free of cost under SRFM, UNA.</p>	<p>To issue reminder to the SE SRFM Una/Firm.</p> <p><b>Action By:</b> Superintending Engineer, JSV Circle SRFM Una</p>
<p><b>D Firms called for technical details on 09.06.2020</b></p>			
2	<p>M/s Falcon Pumps Pvt. Ltd 39/4, Vavdi Ind. Area, Gondal Road, NH-8B, Post: Vavdi Rajkot-360004, Gujrat India</p> <p>Contact No. 91 97277 00566/7, 91 9099953288</p> <p>Email: emss@falconpumps.in</p>	<p>It was decided by the committee that the firm shall undertake a demonstration project under JSV Zone Shimla on a scheme involving high head. The CE(SZ) informed the committee that the submersible pump for high head scheme requiring much space than available at site and hence cannot be installed.</p> <p>The committee directed the CE (SZ) to explore the possibilities for other types of pumps.</p>	<p>To issue reminder to the CE (SZ).</p> <p><b>Action By:</b> The Chief Engineer (SZ).</p>
6	<p>Vendor for Registration for <b>Lecon Energetics</b> Make FCMMA plus Soft Starter and HT Capacitor</p>	<p>It was decided by the committee that the firm shall undertake a demonstration project under JSV Circle Bilaspur.</p>	<p>The Chief Engineer (HZ) intimated the committee that the firm has not contacted the office of SE JSV Circle Bilaspur till date and SE,</p>

	Panels.	<p>Contact No. 91 80 4099 0032, 49523030, 49585549, 91 9449041220 Email: sales@leconsystem.com lecongmg@gmail.com</p>		<p>JSV Circle Bilaspur has proposed to drop the item vide letter No. 2928-30 dated 06.07.2021.  Hence, the committee decided to drop the item.</p>
7	<p>Request for approval and inclusion of " DVEPL make in list of LT Panel/APFC Panel/ac CONTROL Panel/ Pump House Panel/feeder Pillar/ cable junction Boxes/circuit breaker Boxes/ DC Rated Junction Boxes</p>	<p>M/s DV Electronics Pvt. Ltd., Prabhu Niwas Building near Ranbir Petrol Pump Road Patankot-145001. Contact No. 91-186 2231231 Email: <a href="mailto:dvepl@yahoo.in">dvepl@yahoo.in</a> <a href="mailto:info@devpl.com">info@devpl.com</a></p>	<p>It was decided by the committee that the firm shall undertake a demonstration project under JSV Circle Nurpur was decided by the committee that the firm shall undertake a demonstration project under JSV Circle Nurpur</p>	<p>To issue reminder to the SE JSV Circle Nurpur/ firm.  <b>Action By:</b> Superintending Engineer, JSV Circle Nurpur.</p>
10	<p>Regarding water conservation and waste water treatment.</p>	<p>M/s Jaldhara Pvt. Ltd Vill. Oddar PO Banuri Tehsil Palampur, Distt. Kangra. Contact No. 8219655224 9459471992 Email: <a href="mailto:jaldhaarainnodi10@gmail.com">jaldhaarainnodi10@gmail.com</a></p>	<p>The committee asked the firm to submit the cost details of the eSBR technology and its comparison with other technologies to the office of the Superintending Engineer (P&amp;I-I).  The firm has shared the cost details through e mail on 12.01.2021. It is recommended to install free of cost demonstration project at any of existing septic tank in the department. The committee directed the firm to install free demonstration project at existing septic tank in Mandi Town.</p>	<p>To issue reminder to the SE JSV Circle Sundernagar/ firm.  <b>Action By:</b> Superintending Engineer, JSV Circle Sundernagar.</p>

15	Installation of PLC Based Centralized Automatic Bacteriological Treatment Plant with Online Comprehensive Analyzer at the Pump Houses for Supply of Bacteria Free Drinking Water as per BIS Standard Vide IS 10500-2012	M/s Mercury International Pvt. Ltd. CB-1003, Evershine Greens, New Link Road, Oshiwara, Andheri-W, Mumbai 400053. Contact No 022-40145659 Email: <a href="mailto:info@mercuryintl.in">info@mercuryintl.in</a>	It was decided that the firm shall undertake a demonstration project (free of cost) under JSV Circle, Kullu and further action shall be taken on the receipt of performance report from Superintending Engineer, JSV circle Kullu. The firm is directed to report to the office of SE, JSV Circle Kullu.	To issue reminder to the SE JSV Circle Kullu/ firm.
16	Appointment for presentation of our prefabricated water treatment plant technology	M/s Ion Exchange India Ltd., Flat No. 08 Block B, local Shopping Centre Ring Road, Narana Vihar New Delhi-110028. Contact No 91-7018092232 Email: <a href="mailto:jagjeevan.singh@ionexchan.ge.co.in">jagjeevan.singh@ionexchan.ge.co.in</a>	The firm requested to include its product in the Schedule of Rate, therefore, the committee asked the firm to submit the rate analysis, detailed technical specifications, performance evaluation reports from certified Labs and Government Departments/agencies to the office of the Superintending Engineer (P&I-I), Jal Shakti Vibhag, Jal Shakti Bhawan, Shimla - 5.	To issue reminder to the firm.
19	Approval of Forbes Marshall Make PLC/SCADA and Water Quality Analysers (PH/ TDS/ DO/ Conductivity/ Chlorine/ BOD/ COD/ PH/ TSS, Ammonia/ Turbidity etc.	M/s Forbes Marshall Pvt. Ltd., SCF-38, Ph-1 <sup>st</sup> SAS Nagar Mohali, Punjab-160065 Contact No 91-172-2210026 8288020349 Email: <a href="mailto:drdsharma@forbesmarshall.com">drdsharma@forbesmarshall.com</a>	The firm informed the committee that its PLC/ SCADA system has already been installed under Hamirpur Zone, therefore, the committee decided that the Chief Engineer (HZ) will submit the performance evaluation report of the PLC/SCADA installed by the firm. In addition, the firm shall undertake a demonstration project for its Water Quality Analyser products under JSV Circle Hamirpur. Further decision in this regard shall be taken after the receipt of the performance report from the	To issue reminder to the CE(H/Z), SE JSV Circle Hamirpur / firm.

	<p>Superintending Engineer, JSV Circle Hamirpur.</p>	<p>Superintending Engineer, JSV Circle Hamirpur.</p>	<p><b>Action By:</b> Superintending Engineer, JSV Circle Hamirpur</p>
<p>22</p>	<p>Studies to increase in water use efficiency by WAPCOS</p>	<p>It was decided that about 100 locations be selected for monitoring of water quality and quantity (about 25 locations in each zone) with at least one location in each constituency. Thereafter WAPCOS will submit detailed proposal in this regard. Chief Engineer (MZ) submitted the detail of 25 No. Locations vide letter No. 7597-7600 dated 15.09.2020. The Committee requested the Chief Engineer Hamirpur, Shimla and Dharamshala Zone to submit the proposals directly to the Director (WSSO) immediately.</p>	<p>The Committee decided to drop the item.</p>
<p><b>E Firms called for presentation on dated 16.09.2020</b></p>			
<p>1</p>	<p>Introduction of JOHKASOU Technology from Japan for decentralized treatment of domestic wastewater</p>	<p>M/s Daiki Axis India Pvt. Ltd, G-17 DLF Tower B, Jasola, New Delhi-110020. Contact No- 91-9810367527 Email: <a href="mailto:kamal@daiki-axis.com">kamal@daiki-axis.com</a></p>	<p>To issue reminder to the SE JSV Circle Dharampur / firm.</p>
<p>5</p>	<p>Request for approval-Valves and Cocks.</p>	<p>M/s Veeson Valves PVT. Ltd. DPR Lane, Bulandpur Road, Jalandhar-144012 (PB) India. Contact No: 0181-2604750 Email: <a href="mailto:veeson@drpgroup.in">veeson@drpgroup.in</a></p>	<p><b>Action By:</b> Superintending Engineer, JSV Circle Dharampur</p> <p>To issue reminder to the SE Circle Nurpur / firm.</p>
<p><b>Action By:</b> Superintending Engineer, JSV Circle Nurpur</p>			

*M.A.C.*



6	VTM ball Valve, gate valve, sluice valve, check valve, strainer, butterfly valve, steam valves, flow meters, sensors and transmetres.	M/s V.A Valves Udyog Nagar Gadaipur, Jalandhar City Punjab -144004 Contact No: 91-181-2601540, 2601541 Email: <a href="mailto:vavalves@vk-utam.com">vavalves@vk-utam.com</a>	It was decided by the committee that firm shall undertake a demonstration project free of cost under JSV Circle Una.	To issue reminder to the SE JSV Circle Una / firm.  <b>Action By:</b> Superintending Engineer, JSV Circle Una
7	Vendor Registration for Hawle Group (Hawle, Ozkan and Nora Siria Brands) to supply products (Valves and pipe repair clamps with pipe fittings)	M/s Hawle Valves India Pvt Ltd Office No. 10, 2n floor, B wing Aditya Centegra, Shivajinagar FC Road, Pune-411005 Maharashtra, Contact No: 91-9538693709 70205 3156/9908445777 Email: <a href="mailto:indrajit.mukherjee@hawle.i">indrajit.mukherjee@hawle.i</a>	It was decided by the committee that due to wide range of product of the firm, the firm shall initially install 2 or 3 product under JSV Circle Nahan, the same shall be approved after the performance report of the SE JSV Circle Nahan. The SE JSV Circle Nahan intimated vide letter No. 8825-27 dated 13.01.2021 that firm has not contacted this office and neither any correspondence received in this office till date.	To issue reminder to the SE JSV Circle Nahan/ firm.  <b>Action By:</b> Superintending Engineer, JSV Circle Nahan
8	Request for vendor registration for SIGMA FLOW make valves.	M/s Sigma Flow Control India Ltd. Tabacco House, Room #506,5th Floor, 1&2, old Court House Cormner, Kolkata-700001, WB. Contact No. -03322624871 Email: <a href="mailto:enquiry@sigmaflow.in">enquiry@sigmaflow.in</a>	It was decided by the committee that the firm shall undertake a demonstration project of valves and Fitting and coupling free of cost under JSV Circle Solan.	To issue reminder to the SE JSV Circle Solan/ firm.  <b>Action By:</b> Superintending Engineer, JSV Circle Solan

9	Request for approval of ANDRITZ make for centrifugal Pumps.	M/s Andritz Separation and pump Technologies India Pvt Ltd., S.No.389, 400/ 2A, 00/ 2C/ Padur Road, Kattampakkam, Poonamallee, Chennai-600124 Contact No 91-044 4399 04443991111 Email: <a href="mailto:Pump.in@andritz.com">Pump.in@andritz.com</a>	It was decided by the committee that the firm shall undertake a Pilot project by installing centrifugal pump free of cost under JSV Circle Bilaspur. SE JSV Circle Bilaspur has intimated vide letter No. 2961-33 dated 06.07.2021 that the firm has assured to take demonstration project.	To issue reminder to the SE JSV Circle Bilaspur/firm.  <b>Action By:</b> Superintending Engineer, JSV Circle Bilaspur.
11	Regarding approval of Havells make IE2, IE3 three phase LV induction Motors	M/s Havells India Ltd, SCO 12, 1 <sup>st</sup> Floor, 26 Madhya Marg, Chandigarh - 160019 Contact No 0172-4232400-401 Email: <a href="mailto:chandigarh.office@havells.com">chandigarh.office@havells.com</a>	It was decided by the committee that the firm shall undertake a demonstration of their product on Pilot basis free of cost under JSV Circle Nahana. The SE JSV Circle Nahana intimated vide letter No. 8825-27 dated 13.01.2021 that firm has installed 40 HP motor in LIS Kodri Majri Under JSV Division Poanta. The performance of the motor is being observed.	To issue reminder to the SE JSV Circle Nahana/firm.  <b>Action By:</b> Superintending Engineer, JSV Circle Nahana.
13	Request to include Alaska pre insulated pipes in water Supply as an approved brand for drinking water.	M/s Alaska Pre-insulated Systemes 102-Avantika, 35 Chaitanya Society, Opp. Saradar Patel Stadium road, Navrang Pura, Ahamdabad-380009 Gujrat Contact No 079-26467451, Email: <a href="mailto:marketing@alaskapuf.com">marketing@alaskapuf.com</a>	It was decided by the committee that the firm shall undertake a free of cost demonstration project of pre insulated PPR pipes at Kaza in Lahaul & Spiti under JSV Circle R/Peo.	To issue reminder to the SE JSV Circle R/Peo/firm.  <b>Action By:</b> Superintending Engineer, JSV Circle R/Peo

15	Application for empanelment of Meenaar Global Consultants LLP with deptt of JSV Himachal Pradesh as Third Party Inspection.	M/s Meenaar Global Consultants LLP 592/ 16A Faridabad, Haryana-121002 C-8 8327, Vasant Kunj New Delhi-110070 Contact No 91-9810755700 Email: nkn@mgclip.in sales@mgclip.in	The Committee decided that the CE (HZ) shall form a team of official to inspect the facility unit and put up the report.	To issue reminder to the CE(HZ)  <b>Action By: Chief Engineer (HZ)</b>
17	Request for providing us a few minutes to give a brief presentation in the upcoming technical Committee on Roof Top rain water to drinking water ultrafiltration system	M/s Shalimar Enviro Pvt Ltd 608, Pearls Buisness park Netaji Subhash Place Pitampura New Delhi-110034 Contact No 011-47320444, 27357335 9958833334 Email: shalimar.int@gmail.com	Work awarded to firm in D/Z however firm applied for extension of 6 months vide letter No. sep/2101/iph/s04 dated 04.01.2021.	To issue reminder to the CE (DZ)/firm.  <b>Action By: Chief Engineer (DZ)</b>
<b>F Firms called for presentation on dated 13.01.2021</b>				
4	Introduction of efficient water supply pipeline cleaning Technology for the state of HP.  This Technology can clean 5Km pipeline within 10 minutes.	M/s Ssenypanng Co. Ltd Gangseoro Gangseogu-485021, Seoul South Korea D-38, Maxpro Info Park, Industrial Ph-1 <sup>st</sup> SAS Nagar, Mohali Punjab-160057 Contact No 91-7859800007 Email: info@ssenypanngindia.com	The committee decided to send a team of official to visit the demonstration project to be organized at Mumbai on the sponsorship of the firm.  Action to be taken on further communication from the firm.	Matter be kept in abeyance till further communication from the firm.

8	Vendor Approval off our VECTUS PPR, AGRI, SWR, CPCV, Composite pipes and fitting and water storage tanks.	M/s Vectus Industries Limited, A-36, Sector 83, Noida-201305, UP. Contact No. 08288065593 Email: hitesh.aggarwal@vectus.in	The committee decided to allocate a site for demonstration free of cost by the firm under JSV, Circle Solan.	To issue reminder to the SE JSV Circle Solan/firm.
9	Vendor Registration (TOC analyser-TOC, COD, BOD, TSS and others PH and OPR analyser, Dissolved Oxygen meter, Conductivity and Salinity analyser, TDS analyser, Turbidity meter, Digital controller with IP Connectivity, Chloride and Nitrates analyser.)	M/s Nexstream Eco Solution Pvt. Ltd.B1-504, Shivnath Sky City, Padle, Kalyan Shil Road, Thane-421204 Contact No. 7045689974 Email: nextreameco@gmail.com	The committee asked the firm to send the details specifications of make and model and details of approval of other agencies if available, afterward the firm will take a free demonstration of their product.	To issue reminder to the firm.
11	Request for Brand approval and technical presentation of "JYOTTI" for ERW Pipes and tubes, GP Pipes and tubes, Zinc Coated Coils and Wire Rods.	M/s Madhav KRG Limited (JYOTTI Brand) Address: 1003,10th floor, Aggarwal Millenium, Tower-1 Netaji Subhash Place, Pitampura, North West, Delhi-110058 Contact No. +91-1765-500075 Email: info@madhavkrggroup.com	As per the decision taken during the meeting of the committee held on 08-07-2019, the firm was advised to participate in the tendering process of the department for procurement of GI pipes. The committee decided to allocate a site for free of cost demonstration of MSERW pipes and Zinc coated TMT by the firm under JSV, Circle Sundernagar.	To issue reminder to the SE JSV Circle Sundernagar /Firm.
				<b>Action By:</b> Superintending Engineer, JSV Circle Sundernagar

mf.43.

12	Fluid handling Solutions. (Valves and fitting of different material (HDPE,SS,UPVC, Brass, Gun Metal)	M/s JSJ Solutions LLP ST /1106, Satlaj Apartment, Sector A, Block U, Gomtinagar Extension, Lucknow-226010 UP. Contact No.-94174-87777	The committee decided that the firm will send the specifications of their product a/w references and approval in other Govt department to the office of SE (P&I-I) and give a demonstration of their product. The trial was conducted in HQ, the performance of the product has not found.	The Committee decided to drop the item.
14	Registration of Everyday steel storage Pvt. Ltd. (Up gradation of existing pumping station having old main equipment or inefficient ones impacting the water output/utility cost and maintenance to the department.)	M/s Everyday Steel Storage Pvt. Ltd., Plot No. 12, Ecotech-6 Greater Noida, Gautam Budh Nagar UP - 201306 Mob.9810381538 8860123832 Email: pankaj.upadhyay@everydaysteels.com	The committee asked the firm to give a demonstration of their product free of cost under JSV Circle Nahana.	To issue reminder to the SE JSV Circle Nahana/Firm.  <b>Action By:</b> Superintending Engineer, JSV Circle Nahana
19	Advanced jointing technology of McElory fusion machines for repetitive, consistent quality and leak free joints.	M/s McElory Sales Services India Pvt. Ltd.8/4, whitely Layout, Whitefield Bangalore- 560066. Contact No. 080-28454871/73/77	The committee asked the firm to send the detailed specifications of technology and demonstration of technology under JSV, Circle Una.	To issue reminder to the SE JSV Circle Una/Firm.  <b>Action By:</b> Superintending Engineer, JSV Circle Una

#### V. Review of the preferred make list

The committee members were requested to submit their comments regarding addition and deletion of makes in preferred make list of the Department.

Annexure-"A"

List of Participants

4<sup>th</sup> Meeting of State Level Technical Committee for the year 2021-22 held on 07.07.2021 at 3.00 P.M. under the Chairmanship of Engineer-in-Chief (JSV) at Jal Shakti Bhawan, Tutikandi, Shimla -5.

S.No.	Name	Designation
1.	Er. Sushil Justa.	Chief Engineer (SZ)
2.	Er. Sanjeev Kaul.	Chief Engineer (WSSO)
3.	Er. Dharmendra Gill.	Chief Engineer (MZ)
4.	Er. S.K. Sharma.	Chief Engineer (HZ)
5.	Er. Anil Mehta.	Superintending Engineer (P&I)-I
6.	Er. Anil Jaswal	Executive Engineer (D-I),(P&I)-I